

AGENDA

Board of Public Works Meeting

Tuesday, September 26, 2017 - **7:00 p.m.**

Jackson Village Hall

N168W20733 Main Street

Jackson WI 53037

1. Call to Order and Roll Call.
2. Approval of Minutes for August 29, 2017, meeting.
3. Discussion on year-round street parking Georgetown Drive.
4. Update on Chateau Dr Reconstruction Project.
5. Update on Reconstruction of Water and Street Department Building.
 - Cedar Corp Professional Service Proposal – Salt Storage Building.
 - Review of Ventilation System for Vehicle area.
 - Discussion using existing garage doors from old Street Department Building.
6. 2018 Budget Presentation – Building Inspection Department.
7. 2018 - Five (5) year Capital Improvements Program.
8. 2018 – Public Works Equipment Program.
9. 2018 Budget Presentation – Public Works, Water & Wastewater Utilities.
10. Director of Public Works Report.
11. Citizens/Village Staff to address the Board.
12. Adjourn.

Persons with disabilities requiring special accommodations for attendance at the meeting should contact the Village Hall at least one (1) business day prior to the meeting.

It is possible that members of the Village Board may attend the above meeting. No action will be taken by any governmental body at this meeting other than the governmental body specifically referred to in this meeting notice. This notice is given so that members of the Village Board may attend the meeting without violating the open meeting law.

Public Works Report

September 26, 2017

Treatment Plant - Designed Capacity – 1.67 million gallons per day
 Peak Flow Capacity – 6.0 million gallons per day

Year 2015

January	Avg. Flow 667,774 g.p.d.	Min. Flow 617,000 g.p.d.	Max. 713,000 g.p.d.
February	Avg. Flow 620,893 g.p.d.	Min. Flow 591,000 g.p.d.	Max. 662,000 g.p.d.
March	Avg. Flow 753,484 g.p.d.	Min. Flow 597,000 g.p.d.	Max. 885,000 g.p.d.
April	Avg. Flow 1.203 MGD	Min. Flow 705,000 g.p.d.	Max. 3.759 MGD
May	Avg. Flow 775,323 g.p.d.	Min. Flow 584,000 g.p.d.	Max. 1.317 MGD
June	Avg. Flow 905,633 g.p.d.	Min. Flow 661,000 g.p.d.	Max. 1.409 MGD
July	Avg. Flow 696,290 g.p.d.	Min. Flow 571,000 g.p.d.	Max. 912,000 g.p.d.
August	Avg. Flow 726,935 g.p.d.	Min. Flow 558,000 g.p.d.	Max. 1.254 MGD
September	Avg. Flow 728,240 g.p.d.	Min. Flow 526,000 g.p.d.	Max. 1.364 MGD
October	Avg. Flow 505,516 g.p.d.	Min. Flow 409,000 g.p.d.	Max. 691,000 g.p.d.
November	Avg. Flow 696,800 g.p.d.	Min. Flow 494,000 g.p.d.	Max. 1.583 MGD
December	Avg. Flow 897,258 g.p.d.	Min. Flow 616,000 g.p.d.	Max. 1.799 MGD

Year 2016

January	Avg. Flow 611,323 g.p.d.	Min. Flow 451,000 g.p.d.	Max. 924,000 g.p.d.
February	Avg. Flow 640,793 g.p.d.	Min. Flow 496,000 g.p.d.	Max. 851,000 g.p.d.
March	Avg. Flow 821,839 g.p.d.	Min. Flow 567,000 g.p.d.	Max. 1.463 MGD
April	Avg. Flow 718,000 g.p.d.	Min. Flow 563,000 g.p.d.	Max. 1.079 MGD
May	Avg. Flow 615,000 g.p.d.	Min. Flow 490,000 g.p.d.	Max. 937,000 g.p.d.
June	Avg. Flow 622,700 g.p.d.	Min. Flow 513,000 g.p.d.	Max. 892,000 g.p.d.
July	Avg. Flow 690,935 g.p.d.	Min. Flow 457,000 g.p.d.	Max. 1.074 MGD
August	Avg. Flow 1.039 MGD	Min. Flow 822,000 g.p.d.	Max. 1.338 MGD
September	Avg. Flow 1.333 MGD	Min. Flow 813,000 g.p.d.	Max. 2.166 MGD
October	Avg. Flow 1.319 MGD	Min. Flow 949,000 g.p.d.	Max. 2.572 MGD
November	Avg. Flow 1.111 MGD	Min. Flow 859,000 g.p.d.	Max. 1.818 MGD
December	Avg. Flow 1.211 MGD	Min. Flow 889,000 g.p.d.	Max. 2.063 MGD

Year 2017

January	Avg. Flow 1.230 MGD	Min. Flow 979,000 g.p.d.	Max. 1.606 MGD
February	Avg. Flow 1.204 MGD	Min. Flow 926,000 g.p.d.	Max. 2.141 MGD
March	Avg. Flow 1.559 MGD	Min. Flow 1.09 MGD	Max. 2.398 MGD
April	Avg. Flow 1.552 MGD	Min. Flow 1.049 MGD	Max. 2.446 MGD
May	Avg. Flow 1.392 MGD	Min. Flow 666,000 g.p.d.	Max. 2.588 MGD
June	Avg. Flow 1.283 MGD	Min. Flow 763,000 g.p.d.	Max. 2.429 MGD
July	Avg. Flow 1.225 MGD	Min. Flow 879,000 g.p.d.	Max. 1.711 MGD
August	Avg. Flow 1.049 MGD	Min. Flow 750,000 g.p.d.	Max. 1.414 MGD

Years Summary of Water Consumption

2004 Total Pumpage 216,055,000 gallons	2005 Total Pumpage 223,215,000 gallons
2006 Total Pumpage 207,719,000 gallons	2007 Total Pumpage 217,224,000 gallons
2008 Total Pumpage 229,613,000 gallons	2009 Total Pumpage 231,160,000 gallons
2010 Total Pumpage 239,326,000 gallons	2011 Total Pumpage 240,268,000 gallons
2012 Total Pumpage 253,492,000 gallons	2013 Total Pumpage 228,371,000 gallons
2014 Total Pumpage 230,973,000 gallons	2015 Total Pumpage 222,621,000 gallons
2016 Total Pumpage 254,531,000 gallons	

Year 2015

Jan.	Avg.	599,680 g.p.d.	Highest Day 719,000 gals.	Total	18,590,000 gallons
Feb.	Avg.	587,040 g.p.d.	Highest Day 736,000 gals.	Total	16,437,000 gallons
March	Avg.	582,970 g.p.d.	Highest Day 698,000 gals.	Total	18,072,000 gallons
April	Avg.	601,370 g.p.d.	Highest Day 928,000 gals.	Total	18,041,000 gallons
May	Avg.	585,260 g.p.d.	Highest Day 698,000 gals.	Total	18,143,000 gallons
June	Avg.	640,430 g.p.d.	Highest Day 779,000 gals.	Total	19,213,000 gallons
July	Avg.	722,550 g.p.d.	Highest Day 989,000 gals.	Total	22,399,000 gallons
August	Avg.	733,420 g.p.d.	Highest Day 1.197 MGD	Total	22,736,000 gallons
Sept	Avg.	615,700 g.p.d.	Highest Day 753,000 gals.	Total	18,471,000 gallons
Oct	Avg.	594,840 g.p.d.	Highest Day 945,000 gals.	Total	18,440,000 gallons
Nov	Avg.	492,630 g.p.d.	Highest Day 599,000 gals.	Total	14,779,000 gallons
Dec	Avg.	555,480 g.p.d.	Highest Day 637,000 gals.	Total	17,220,000 gallons

Year 2016

Jan.	Avg.	580,680 g.p.d.	Highest Day 734,000 gals.	Total	18,001,000 gallons
Feb.	Avg.	603,930 g.p.d.	Highest Day 710,000 gals.	Total	17,514,000 gallons
March	Avg.	586,650 g.p.d.	Highest Day 693,000 gals.	Total	18,186,000 gallons
April	Avg.	660,200 g.p.d.	Highest Day 1.021 MGD	Total	19,806,000 gallons
May	Avg.	681,130 g.p.d.	Highest Day 997,000 gals.	Total	21,115,000 gallons
June	Avg.	781,870 g.p.d.	Highest Day 1.113 MGD	Total	23,456,000 gallons
July	Avg.	865,610 g.p.d.	Highest Day 1.046 MGD	Total	26,834,000 gallons
August	Avg.	817,940 g.p.d.	Highest Day 1.084 MGD	Total	25,356,000 gallons
Sept	Avg.	700,630 g.p.d.	Highest Day 835,000 gals.	Total	21,019,000 gallons
Oct	Avg.	738,520 g.p.d.	Highest Day 1.235 MGD	Total	22,894,000 gallons
Nov	Avg.	654,530 g.p.d.	Highest Day 829,000 gals.	Total	19,636,000 gallons
Dec	Avg.	668,190 g.p.d.	Highest Day 779,000 gals.	Total	20,714,000 gallons

Year 2017

Jan.	Avg.	630,710 g.p.d.	Highest Day 771,000 gals.	Total	19,552,000 gallons
Feb.	Avg.	640,790 g.p.d.	Highest Day 885,000 gals.	Total	17,942,000 gallons
March	Avg.	611,520 g.p.d.	Highest Day 691,000 gals.	Total	18,957,000 gallons
April	Avg.	703,070 g.p.d.	Highest Day 1.173 MGD	Total	21,092,000 gallons
May	Avg.	683,420 g.p.d.	Highest Day 988,000 gals.	Total	21,186,000 gallons
June	Avg.	762,230 g.p.d.	Highest Day 1.044 MGD	Total	22,867,000 gallons
July	Avg.	730,580 g.p.d.	Highest Day 953,000 gals.	Total	22,648,000 gallons
August	Avg.	745,900 g.p.d.	Highest Day 903,000 gals.	Total	23,123,000 gallons

Pump Capacity - Well #1- 400 g.p.m. Well #3 -900 g.p.m. Well #4 - 1200 g.p.m. Well #5 – 1,100 g.p.m. Well #6 – 800 g.p.m.

WWTP – Holding & Septage Receiving

2005	\$ 87,562.01	2006	\$101,115.11	2007	\$152,201.07	2008	\$210,441.47
2009	\$183,815.34	2010	\$197,653.66	2011	\$220,576.28	2012	\$236,224.70
2013	\$235,336.46	2014	\$203,938.32	2015	\$210,644.47	2016	\$220,473.17

2015	Holdings (gals)	Grease (gals)	G Decant (gals)	Septage (gals)	S Decant (gals)	Total Billings
Jan	1,326,850			10,250	52,100	\$11,663.89
Feb	1,191,500			2,500	45,400	\$10,171.26
March	1,507,900			16,150	85,900	\$14,102.76
April	1,668,450			35,250	398,200	\$23,878.38
May	1,190,850			31,100	148,600	\$13,890.38
June	1,407,600			37,750	349,100	\$20,794.50
July	1,485,950			33,830	243,660	\$18,589.33
August	1,255,600			28,050	290,860	\$17,810.50
September	1,459,400			15,500	333,350	\$19,899.26
October	1,273,400	7,200		37,150	369,300	\$20,603.82
November	1,336,300			36,200	343,035	\$20,046.14
December	1,610,500			31,200	234,700	\$19,194.26

2016	Holdings (gals)	Grease (gals)	G Decant (gals)	Septage (gals)	S Decant (gals)	Total Billings
Jan	1,359,400			3,500	47,700	\$11,528.02
Feb	1,443,000			1,500	31,350	\$11,666.26
March	1,515,950			5,600	102,900	\$14,166.14
April	1,600,500			25,000	284,250	\$20,110.01
May	1,560,350			24,000	246,200	\$18,817.63
June	1,551,600			49,100	257,900	\$20,048.50
July	1,195,900			21,850	278,400	\$16,803.25
August	1,506,850			29,750	276,250	\$19,397.63
September	1,501,850			48,550	373,430	\$22,541.63
October	1,447,150			126,250	389,054	\$25,629.98
November	1,471,800			40,900	343,250	\$21,255.76
December	1,657,250			11,250	225,160	\$18,508.38

2017	Holdings (gals)	Grease (gals)	G Decant (gals)	Septage (gals)	S Decant (gals)	Total Billings
Jan	1,287,450			10,500	57,100	\$11,503.39
Feb	1,358,400		28,500	1,750	78,550	\$13,361.76
March	1,678,850		22,000	28,100	174,900	\$18,967.89
April	1,581,350			35,600	320,900	\$21,306.63
May	1,745,550			51,150	394,600	\$25,002.63
June	1,664,600			38,700	321,950	\$22,081.26
July	1,599,070			33,100	230,150	\$19,070.78
August	1,669,850			35,100	273,850	\$20,774.14

Final Lift for Developed Subdivisions

Due to only one bidder, the recommendation is to bid the overlays next year.

Rosewood Drive/TIF Expansion Project

The property still has the potential of being developed. A new property owner has a proposal to purchase the property. Also, Washington County is planning on reconstructing CTH P in the same area. We are in discussion with the county on how the sewer and water will be installed across CTH P.

GIS Program

Town and Country Engineering continue to work on the maps, and getting the tablets ready for accessing the maps. An instructional meeting for staff is being scheduled to increase map usage. The opportunity when coming back from the Water Conference to visit with Town & Country in their Madison office to review the database and map corrections that were holding up the project. We are back on track and will start allowing more usage of the maps.

Storm Water Management Plan

We will continue to monitor the system per the Storm Water Management Plan. The plan was submitted at the deadline of June 30, 2017. DNR has not responded on the submitted plan. The Mid-Moraine Collective Group is working a possible group storm water permit. No change.

SCADA Upgrade Project

A pre-con meeting was held on Monday, September 18th for the SCADA project. Piper Electric has started with conduit installation and wiring. The project will get really rolling mid-October with a completion scheduled for mid-December.

Wilshire Drive Project LRIP

The project has been closed out, and the Village has completed the necessary landscaping.

Space Needs Analysis Study

Cedar Corp team continues to meet with staff in developing plans for a new Safety Building. The new professional service proposal is placed on hold until the land purchase is completed..

Chateau Drive Reconstruction Project

The contractor (Buteyn Peterson) for the Chateau Drive Reconstruction met with Village staff and the inspector from Gremmer & Associates for a walkthrough of the project for the creation of a new punch list on Monday, September 18th. The contractor now understands the importance of good landscaping for the project. North Farms is being required by the General Contractor to finish the landscaping.

CTH P and STH 60 Intersection Project

An email will be created and sent to WisDOT on ownership. No change.

Alcan Drive, Alcan Court, & Delaney Court

All contracts have been signed, and street lights will be installed starting the week of September 25th. The paving and curb repair will follow.

Respectfully submitted, Brian W. Kober, P.E.